

GOVERNMENT OF ANDRA PRADESH

ABSTRACT

Revenue (DM) Department – Expenditure of Rs. 5,53,954/- to be met towards supply of 7 Nos. of Online U.P.S., along with batteries with 5 hours backup for the use of Revenue (DM) Department - Sanction Orders – Issued.

[illegible]**REVENUE (DM-IV) DEPARTMENT**

G.O.Ms.No. 3.

Dated: 24 -02-2010.

Read the following:-

1. Govt. Letter No. 19661/DM-IV/2009, Rev. (DM-IV) Dated 07-08-2009.
2. From the Manager, APTS., Hyderabad Letter No. APTS/HWP/DEPT-CORR/2007, Dated 17-08-2009.

ORDER:

Sanction is hereby accorded for an amount of Rs. 5,53,954/- (Rupees Five Lakh Fifty Three Thousand Nine Hundred and Fifty Four only) to the Managing Director, A.P., Technology Services Limited, Hyderabad towards supply of seven (7) 2KVA Online UPS with 5 hours backup for the use of Revenue (DM) Department. The specifications of the required UPS is enclosed herewith for necessary action.

2. The expenditure sanctioned in para (1) above, shall be debited to the Head of Account “ 2245 – Relief on account of Natural Calamities, 80 – General, 102 – Management of Natural Disaster Contingency Plan in Disaster Prone Areas – SH (04) – Disaster Management – 520 – Machinery and Equipment – 521 – Purchases.
3. The amount sanctioned above shall be adjusted to the P.D. Account of Andhra Pradesh Technology Services Limited, Hyderabad (P.D. Account No. 23 / APTS) (Credit Head: 8449 – Other Deposits, 120- Miscellaneous Deposits, 56 Deposits of APTS Ltd.)
4. This order does not require the concurrence of the finance Department.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF ANDHRA PRADESH)

**T. RADHA,
COMMISSIONER FOR DISASTER MANAGEMENT &
EX-OFFICIO PRINCIPAL SECRETARY TO GOVERNMENT**

To

The Managing Director , APTS, Hyderabad (w.e.)

The Deputy Pay and Accounts Officer, Secretariat, Hyderabad.

The DM-Accounts – I Department.

Stock file /Spare

//FORWARDED BY ORDER//

SECTION OFFICER

SPECIFICATIONS

1. U.P.S.

Capacity

Input

Output – in mains mode

In version Voltage

Output Wave form

Charging current

Protections

: 7 Nos.

: 2.0 KVA/24 VDC

: 120 V – 280 V

: 220V+/-10% (5 step AVR)

: 220V+/-3%

: Pure Sine wave

: 10 – 15 amps.

: Protections against over Voltage
Under voltage, Low battery.
2. Batteries

(7 Nos)

Make of the UPS

Electrical Wiring

: 2 Nos. 12 V/100 AH Exide Make SMF batteries.

: APC/Compact/Emerson

: Required input/out wiring should be
done by the supplier.